

Guideline

A-33

CLAP

FORM N°X036

Version : 1

Directive 2014/68/EU

Adopted by WGP : 15/03/2016

Adopted by CLAP : 15/03/2016

Directive References: Article 1 § 2 (s)

Subject: Scope – Receptacles pi marked

Question: Can receptacles (in the meaning of Article 2 of Transportable Pressure Equipment Directive) that are “pi” marked be used as static pressure equipment without being CE marked?

Answer: Yes, provided the PI (π) marked receptacle has been placed on the market and used as transportable pressure equipment, it can then be used permanently as static pressure equipment without being CE marked.

Note 1: For static use the receptacle may be subject to national regulations dealing with conditions of use, installation and periodic inspection (see also Article 3 of TPED 2010/35/EU – On-site requirements).

Note 2: The term “static pressure equipment” has to be understood as “pressure equipment under the scope of Pressure Equipment Directive”, even though these receptacles fall under Article 1 paragraph 2 (s) of PED.

Note 3: See PED Guideline A-30 (CLAP X034) for receptacles with double CE-mark and π mark.

2019-12-30