

Guideline

B-12

CLAP

FORM N°X069

Version : 1

Directive 2014/68/EU

Adopted by WGP : 15/03/2016

Adopted by CLAP : 15/03/2016

Directive References: Article 2 (9)

Subject: Classification – Maximum allowable temperature, TS

Question: For warm water boilers which are controlled by a temperature thermostat and protected by a safety temperature limiter does the maximum allowable temperature (TS) mean:
(a) the maximum intended operating temperature under normal conditions as controlled by the thermostat; or;
(b) the temperature setting of the ultimate over-temperature safety device i.e. the limiter ?

Answer: (b) is correct.

Note: manufacturers must ensure that the equipment is sufficiently robust to deal with any residual heat after activation of the limiter.

See also Guideline B-05 (CLAP X063).

2019-12-31