

**Guideline**

**B-37**

**CLAP**

**FORM N°X087**

**Version : 1**

**Directive 2014/68/EU**

**Adopted by WGP :** 15/03/2016

**Adopted by CLAP :** 15/03/2016

**Directive References:** Article 2 (3)

Article 2 (5)

**Subject:** Classification – Condensate trap

**Question:** How to consider, for the application of PED, a condensate trap installed on piping?

**Answer:**

A condensate trap is intended to play an operational role which is the collection of condensates. Therefore it is generally considered as a pressure accessory, placed on the market with CE marking where appropriate.

However, a condensate trap specifically designed and manufactured as a part of a given item of piping may be assessed as part of the whole piping and, in that case, is not subject to individual CE marking.