

Guideline

C-05

CLAP

FORM N°X092

Version : 1

Directive 2014/68/EU

Adopted by WGP : 08/01/2016

Adopted by CLAP : 08/01/2016

Directive References:

Article 4 § 2

Article 19 § 1

Annex II Table 4

Subject: Assemblies – Derogation of Article 4, paragraph 2

Question: Shall the assemblies defined in the derogation in Article 4, paragraph 2, subparagraph 2 (boilers intended for generating warm water at temperatures not higher than 110°C) carry the CE-marking?

Answer: Yes, in accordance with Article 19 paragraph 1, but the identification mark of the notified body is left out if the manufacturer has selected the use of module B EU-Type examination – Design type.

Reasons: The applied conformity assessment procedure is defined in table 4 of the Annex II, where the modules B EU-Type examination – Design type and H are given as alternatives (see below table). In the case of module B EU-Type examination – Design type, there is no notified body involved at the production control phase, and according to article 19 paragraph 4 no identification number of the notified body shall follow the CE marking.

NOTE: Assemblies as defined in the derogation in Article 4 paragraph 2 subparagraph 2 (boilers intended for generating warm water at temperatures not higher than 110°C) to be CE-marked shall comprise, as a minimum, the boiler with its protection devices.