

Guideline

I-08

CLAP

FORM N°X187

Version : 1

Directive 2014/68/EU

Adopted by WGP : 08/01/2016

Adopted by CLAP : 08/01/2016

Directive References:

Article 19 § 2

Article 4 § 1 (c)

Annex 1§3.3 (c)

Subject: Miscellaneous – Piping part of an industrial installation

Question:

Conformity with the PED is required for some piping per Article 4 paragraph 1 (c), which are part of an industrial installation. May all such piping for a given installation be covered by a single CE marking?

Answer:

Yes, providing the CE marking is prominently displayed and the accompanying documentation supplied by the manufacturer to the user clearly defines the boundary of the installation.