Guideline

8/4

CLAP

FORM N°61

		version: 6	
	Kannanda - Biskandair		
Directive	e 97/23/EC Keywords : Risk analysis Pressure		
	Essential requirements		
Directive references: Annex I Preliminary observation - 97/23 EC			
Adopted by WPG: 08/11/1999 Adopted by CLAP: 08/11/1999			
Subject:	ESR particular – Hazard analysis		
	What shall be the extent of the hazard analysis specified in the third prelimit Annex I?	nary observation of	
Question:			
	How shall it be documented?		
Answer:	The hazard analysis shall enable the manufacturer to identify and to determ	ine the notential	
Allower.	modes of failure due to loading of pressure equipment which could occur when this equipment is		
	installed and used in reasonably foreseeable operating conditions.		
	After the manufacturer has fixed the limits of the equipment, he must complete a hazard analysis		
	which will enable him to identify the essential requirements which are applicable to the equipment.		
	The results of this analysis (applicable essential requirements in relation to the foreseeable		
	operating conditions) shall be included in the technical documentation, but the inclusion of full		
	details of the analysis in the documentation is not required by PED.		
	REMARQUE for the French version only In the third preliminary observation of annex I, in the		
	French version, one shall read "phenomènes dangereux" instead of "risque" in accordance with		
	the English version (hazard) and the german one.		
	Modifications compared to the previous adopted version: copy of guideline	8/4 (08/11/99) and	
	editorial correction on 2004-09-16.	774 (00/11/00) and	